



CERTIFICATE OF PRODUCT CERTIFICATION

CHINA CERTIFICATE FOR ENERGY CONSERVATION PRODUCT

CERTIFICATE NO.: CQC22701343687

Valid from: Jun.06,2022

Valid until: Jun.05,2027

NAME AND REGISTERED ADDRESS OF THE APPLICANT	SHENZHEN CONSNANT TECHNOLOGY CO.,LTD BUILDING NO.B6, JUNFENG INDUSTRIAL PARK,YONGHE ROAD,FUYONG TOWN,BAO`AN DISTRICT,SHENZHEN CITY,GUANGDONG
BRAND NAME	CONSNANT
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	SHENZHEN CONSNANT TECHNOLOGY CO.,LTD BUILDING NO.B6, JUNFENG INDUSTRIAL PARK,YONGHE ROAD,FUYONG TOWN,BAO`AN DISTRICT,SHENZHEN CITY,GUANGDONG
NAME AND LOCATION OF THE FACTORY	SHENZHEN CONSNANT TECHNOLOGY CO.,LTD BUILDING NO.B6, JUNFENG INDUSTRIAL PARK,YONGHE ROAD,FUYONG TOWN,BAO`AN DISTRICT,SHENZHEN CITY,GUANGDONG
PRODUCT NAME,	UPS
MODEL AND SPECIFICATION	See Appendix
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	CQC3108-2011
TYPE OF CERTIFICATION SCHEMES	Product Testing + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of CQC31-461234-2009.

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦

CHINA QUALITY CERTIFICATION CENTRE



CERTIFICATE OF PRODUCT CERTIFICATION

CHINA CERTIFICATE FOR ENERGY CONSERVATION PRODUCT

CERTIFICATE NO. : CQC22701343687

page 1 of 1

paper:

This certificate and attachments shall be used at the same time, and the verification instructions can be found in the main certificate.

Model	Input	Output	Rated capacity	Size
CNG330 10kVA	3Φ+N+PE 380Vac, 17A,50/60Hz	3Φ+N+PE 380Vac, 15A,50/60Hz	10kVA/8kW power factor 0.8	540*657*1132mm
CNG330 20kVA	3Φ+N+PE 380Vac, 34A,50/60Hz	3Φ+N+PE 380Vac, 30A,50/60Hz	20kVA/16kW power factor 0.8	540*657*1132mm
CNG330 30kVA	3Φ+N+PE 380Vac, 51A,50/60Hz	3Φ+N+PE 380Vac, 45A,50/60Hz	30kVA/24kW power factor 0.8	540*657*1132mm
CNG330 40kVA	3Φ+N+PE 380Vac, 68A,50/60Hz	3Φ+N+PE 380Vac, 61A,50/60Hz	40kVA/32kW power factor 0.8	540*657*1132mm
CNG330 50kVA	3Φ+N+PE 380Vac, 85A,50/60Hz	3Φ+N+PE 380Vac, 76A,50/60Hz	50kVA/40kW power factor 0.8	555*725*1290mm
CNG330 60kVA	3Φ+N+PE 380Vac, 102A,50/60Hz	3Φ+N+PE 380Vac, 91A,50/60Hz	60kVA/48kW power factor 0.8	801*731*1400mm
CNG330 80kVA	3Φ+N+PE 380Vac, 136A,50/60Hz	3Φ+N+PE 380Vac, 122A,50/60Hz	80kVA/64kW power factor 0.8	540*657*1132mm



CHINA QUALITY CERTIFICATION CENTRE